

## RFQ-094 Yakima Valley Libraries – Retro-Fit T 8’s with LED Tubes

Hello Vendors,

I have received additional questions about our RFQ-094 (lighting project for Yakima Valley Libraries:

5. Is there an official bid sheet  
No there is not an official bid sheet
6. Since you need to work nights, when does the library close/open  
Library closes at: (Mon. - Wed. 7 pm); (Thur. – Sat. 6 pm); (Sun. at 5 pm) – You must be out of the building by 6:30 am each day
7. Please explain, Schedule the installation during closed hours, with no more than 3 days/nights off during a 7 day period of time, does this mean we can work 4/10 hours shifts at night  
We do not want a vendor to start the project and then leave for an extended period of time before finishing, dragging the project out to multiple weeks. If you wish you can work 10 hour shifts. You need to start after closing & have your equipment, supplies & crew out of the library prior to our cleaning crew starting at 6:30 am each morning.

- 
1. What is the existing wattage? 32W?  
Yes, 32W
  2. How are the existing fixtures hung? Ceiling Surface Mount, Chain, Flush Mount, etc.  
All of our lights are: “Surface Mounted”
  3. Does the existing fixture have a lens?  
Yes, per the scope of work: (Wipe down lens of each light fixture (inside & outside)
  4. Is it possible to get pictures if we can’t make it out there on 2/20?  
See below:



**HIGH CEILING AREA**



**SOUTH END AREA**

Susan Miller  
Facilities Manager  
**Yakima Valley Libraries**  
Facilities Department

[www.yvl.org](http://www.yvl.org)

