

Questions and answers to RFQ-102 Amended Dedicated Power and Additional Outlet at the Naches Library

12/3/2020

- 1.) How far away is the electrical panel from the network closet? [Approximately 46 feet](#)
- 2.) Is there a drop ceiling between the electrical panel & network closet to conceal the new wiring or would it have to run in an attic or crawl space? [On the City of Naches side, there is no drop ceiling. On the Naches Library side, there is a drop ceiling. Pictures are attached of the electrical panel, the ceiling on the City of Naches side, and the back wall and drop ceiling of the Naches Library side opposite of the electrical panel.](#)
- 3.) Is there any cement or masonry walls we will need to drill through to route the dedicated circuit? [A brick wall separates the library from the room with the electrical panel. There is a picture showing the wall and ceiling above the electrical panel between the City of Naches and Naches Library.](#)
- 4.) Can you provide a picture of the existing electrical panel? [Attached.](#)
- 5.) Can you provide a picture of the location you want the outlet installed in the network closet? [Attached.](#)
- 6.) Can you provide a picture of where you want the additional outlet installed? [Attached.](#)