

Round 2 of questions and answers to RFQ-115b 2022 Electrical Outlets at Buena:

1. If we are blanking off the existing outlets is there any reason we cannot extend those circuits to the new location and reuse them versus new circuits?

No, the existing circuits cannot be reused. We want the option to reuse those circuits and outlets in the future.

2. When you say two outlets do you mean (1) duplex outlets or (2) duplex outlets)? The existing outlets are (1) duplex outlet.

We would like to have 2 separate duplex outlets. There are currently 2 separate duplex outlets approximately 2 feet apart.

3. If you mean (1) duplex outlet can we reuse the existing duplex outlet covers at the new location?

The existing outlet covers can be reused for the new location.

4. Would this work be completed during normal business hours?

Hours available to work on this project would be Monday through Friday from 7 a.m. to 1 p.m., but would need to be scheduled.