

Equipment Number	Type	Make	Model Number	Size	Serial Number	Year	Location - Area Served	Belts	Filters (Nominal Size)
DDC-01	DIGITAL CONTROL	MITUSBISHI	VRF DIGITAL CONTROLS		N/A	2010			
EF-01	EXHAUST FAN	GENERAL ELECTRIC	K5182AG201		N/A	0	ROOF Mechanical Room - RESTROOM EXHAUST FAN	2 - 4L720 BELTS or A-70	
FC-01A (IC-15)	VRF ID UNIT	MITSUBISHI	PEFY-P48NMAU-E	4 TON	9ZW00136	2010	BASEMENT Programming - KIDS ROOM / SOUTH LIBRARY (Quad Stack - middle bottom)		Pleated Filters: 2 - 9x20x2; 1 - 9x16x2
FC-01B (IC-16)	VRF ID UNIT	MITSUBISHI	PEFY-P48NMAU-E	4 TON	91W00167	2010	BASEMENT Programming - KIDS ROOM / SOUTH LIBRARY (Quad Stack - bottom)		Pleated Filters: 2 - 9x20x2; 1 9x16x2
FC-02 (IC-11)	VRF ID UNIT	MITSUBISHI	PCFY-P24NKMU-E	2 TON	97A00017D	2010	BASEMENT IT - SERVER ROOM		Washable Filters
FC-03 (IC-12)	VRF ID UNIT	MITSUBISHI	PEFY-P48NMAU-E	4 TON	93W00263	2010	BASEMENT Programming - ACCOUNTING		Pleated Filter: 1 - 18x30x2
FC-04 (IC-09)	VRF ID UNIT	MITSUBISHI	PEFY-P96NMHU-E	8 TON	92W00719	2010	BASEMENT ADA Elevator - FRONT LIBRARY		Pleated Filters: 2 - 12x18x2
FC-05A (IC-13)	VRF ID UNIT	MITSUBISHI	PEFY-P48NMAU-E	4 TON	92W00213	2010	BASEMENT Programming - KIDS ROOM / SOUTH LIBRARY (Quad Stack - top)		Pleated Filters: 2 - 9x20x2; 1 9x16x2
FC-05B (IC-14)	VRF ID UNIT	MITSUBISHI	PEFY-P48NMAU-E	4 TON	9ZW00137	2010	BASEMENT Programming - KIDS ROOM / SOUTH LIBRARY (Quad Stack - middle top)		Pleated Filters: 2 - 9x20x2; 1 9x16x2
FC-06 (IC-06)	VRF ID UNIT	MITSUBISHI	PEFY-P96NMHU-E	8 TON	99W00569	2010	BASEMENT Dumbwaiter - FRONT LIBRARY		Pleated Filters: 2 - 16x20x2
FC-07 (IC-01)	VRF ID UNIT	MITSUBISHI	PEFY-P72NMHU-E	6 TON	92W00935	2010	BASEMENT by hidden Stairs - FRONT LIBRARY		Pleated Filters: 2 - 16x20x2
FC-08 (IC-02)	VRF ID UNIT	MITSUBISHI	PEFY-P48NMHU-E	4 TON	92W01972	2010	BASEMENT Outside IT Cage - BOARDROOM		Pleated Filter: 1 - 8x24x2

FC-09 (IC-03)	VRF ID UNIT	mitsubishi	PEFY-P15NMHU-E	1-1/4 TON	92W01237	2010	BASEMENT in IT Cage - DIRECTORS OFFICE		Pleated Filter: 1 - 14x24x2
---------------	-------------	------------	----------------	-----------	----------	------	--	--	-----------------------------

Equipment Number	Type	Make	Model Number	Size	Serial Number	Year	Location - Area Served	Belts	Filters (Nominal Size)
FC-10 (IC-04)	VRF ID UNIT	MITSUBISHI	PDFY-P08NMU-E	3/4 TON	97W01711	2010	BASEMENT in IT Cage - HR OFFICE		Pleated Filter: 1 - 12x25x2
FC-11 (IC-05)	VRF ID UNIT	MITSUBISHI	PEFY-P24NMHU-E	2 TON	92W02327	2010	BASEMENT Outside Facilities Office - MAIN BASEMENT AREA		Pleated Filter: 1 - 16x25x2
FC-12 (IC-07)	VRF ID UNIT	MITSUBISHI	PEFY-P15NMHU-E	1-1/4 TON	92W01238	2010	FIRST FLOOR CEILING Admin. Office ADMIN. OFFICE		Pleated Filter: 1 - 13x24x2
FC-13 (IC-08)	VRF ID UNIT	MITSUBISHI	PEFY-P18NMHU-E	1-1/2 TON	04W01623	2010	BASEMENT TUNNEL Ceiling/horizontal - BREAKROOM		Pleated Filter: 1 - 14x24x2
FC-14 (IC-10)	VRF ID UNIT	MITSUBISHI	PVfy-P36E00A	3 TON	R0309100133	2010	BASEMENT TUNNEL Floor/vertical - NORTH STAFF AREA		Pleated Filter: 1 - 12-1/2x28x2
FC-15A (IC-18)	VRF ID UNIT	MITSUBISHI	PEFY-P96NMHU-E	8 TON	04W00820	2010	BASEMENT Lower Fan Room - READING ROOM/LIBRARY (Dual Stack - top)		Pleated Filters: 1 - 16x20x2 1 - 16x23-1/2x2
FC-15B (IC-19)	VRF ID UNIT	MITSUBISHI	PEFY-P96NMHU-E	8 TON	9XW00576	2010	BASEMENT Lower Fan Room - READING ROOM/LIBRARY (Dual Stack - bottom)		Pleated Filters: 1 - 16x20x2 1 - 16x23-1/2x2
FC-16 (IC-20)	VRF ID UNIT	MITSUBISHI	PEFY-P96NMHU-E	8 TON	92W00720	2010	FIRST FLOOR Ceiling Northwest Reading Room - SOUTH STAFF AREA		Pleated Filters: 2 - 16x20x2

FC-17 (IC-17)	VRF ID UNIT	mitsubishi	PKFY-P06NBMU-E	1/2 TON	97A00298D	2010	BASEMENT Programming - PROGRAMMING		Washable Filters
HRU-01	HEAT RECOVER	RENEWAIRE	PA9XIN (PA-9XJIN9)		G105858C	2010	ROOF Mechanical Room		Pleated Filters: 18 - 20x20x2
RF-01	RETURN FAN	DAYTON	3KV87G		ETP6085009012	0	BASEMENT North Lower Fan Room	1-B210 BELTS (Matched set of 5)	
SF-01	SUPPLY FAN	GENERAL ELECTRIC	5K4326A3		PN18559	0	BASEMENT South Lower Fan Room	3 - C195 BELT	

Equipment Number	Type	Make	Model Number	Size	Serial Number	Year	Location - Area Served	Belts	Filters (Nominal Size)
SF-02	SUPPLY FAN	COOK	195SQN195SQNB		033SD274200000701	2010	BASEMENT Store - KIDS ROOM/SOUTH LIBRARY	2 - A90 BELT	
UH-01	DUCT HEATER	STERLING	QVSD-175-M (Unit #SSUDD3175A2N2AH100)		H1001016241001001	2010	ROOF Mechanical Room Ceiling		
VRF-01-1 (OC-62)	VRF OD UNIT	mitsubishi	PURY-P120YJMU-A	10 TON	04W00246	2010	ROOF / VRF-1-BC (VRF- BC-63)		
VRF-01-2 (OC-61)	VRF OD UNIT	mitsubishi	PURY-P120YJMU-A	10 TON	04W00215	2010	ROOF / VRF-1-BC (VRF- BC-63)		
VRF-02 (OC-57)	VRF OD UNIT	mitsubishi	PURY-P120YJMU-A	10 TON	04W00238	2010	ROOF / VRF-2-BC (VRF- BC-59)		
VRF-03-1 (OC-52)	VRF OD UNIT	mitsubishi	PURY-P120YJMU-A	10 TON	04W00385	2010	ROOF / VRF-3-BC (VRF- BC-3)		
VRF-03-2 (OC-51)	VRF OD UNIT	mitsubishi	PURY-P120YJMU-A	10 TON	04W00278	2010	ROOF / VRF-3-BC (VRF- BC-3)		
VRF-04-1 (OC-69)	VRF OD UNIT	mitsubishi	PURY-P120YJMU-A	10 TON	04W00388	2010	ROOF / VRF-4-BC (VRF- BC-70)		
VRF-04-2 (OC-68)	VRF OD UNIT	mitsubishi	PURY-P120YJMU-A	10 TON	05W00394	2010	ROOF / VRF-4-BC (VRF- BC-70)		
VRF-BC-01 (BC-63)	VRF BC CONTROL	mitsubishi	CMB-P108NU-GA		93W01450	2010	South Fan Room / (VRF- BC-63) SERVES: (IC- 11,12,13,14,15,16,17) F/C #S 1,2,3,5 & 17		

VRF-BC-02 (BC-59)	VRF BC CONTROL	mitsubishi	CMB-P108NU-GA		04W00763	2010	North Fan Room / SERVES: (IC- 18,19,20) F/C #S 4,12,13 & 14		
VRF-BC-03 (BC-53)	VRF BC CONTROL	mitsubishi	CMB-P108NU-GA		91W00738	2010	North-Center Basement / SERVES: (IC- 7,8,9,10) (OC-57) F/C #S 6,7,8,9,10 & 11		
VRF-BC-04 (BC-70)	VRF BC CONTROL	mitsubishi	CMB-P108NU-GA		93W01447	2010	South Fan Room / SERVES: (FC- 7,8,9,10,11) F/C #S 15 & 16		
(EF-02)	EXHAUST FAN	GREENHECK	CWB-099-4-X		12807865 1204	2012	ROOF SW side / Public Bathrooms	1 - 3L190 BELT	
(GEF-01)	EXHAUST FAN	BREIDERT	BW-404 B				ROOF NW side / Garage Exhaust	1 - A-35 BELT	