

# Questions & Answers for RFQ-123

RFQ-123 - YVL Annual Fire Extinguisher Certification

**Q #1:** Do you know what category this work falls under with L & I?

**A #1:** L & I [Sprinkler Fitters](#) (Fire Protection). You can open the hyperlink to be directed to the L & I website for this category. You would select Yakima County & Sprinkler Fitters.

- Just a reminder, prevailing wage only applies to the fire extinguishers that you service inside our buildings. The fire extinguishers we deliver to you will not fall under prevailing wage law.



The screenshot shows the Washington State Legislature website page for WAC 296-127-01375. The page title is "WASHINGTON STATE LEGISLATURE" and the page content includes the following text:

WACs > Title 296 > Chapter 296-127 > Section 296-127-01375

HTML has links - PDF has Authentication

Print This Page

296-127-01374 << 296-127-01375 >> 296-127-01376

No agency filings affecting this section since 2003

PDF WAC 296-127-01375

**Sprinkler fitters.**

For the purpose of the Washington state public works law, chapter 39.12 RCW, sprinkler fitters perform the installation, adjustments and corrections, maintenance, repair and dismantling of all fire protection and fire control systems and the installation of all piping for tubing, appurtenances and equipment pertaining thereto.

The work includes, but is not limited to:

- (1) Underground water mains, fire hydrants and hydrant mains, stand pipes and hose connections to sprinkler systems and overhead piping.
- (2) Sprinkler tank heaters.
- (3) Air lines and thermal systems used in connection with sprinkler and alarm systems and all tanks and pumps connected thereto.
- (4) Co<sup>2</sup> and carbox systems, dry chemical systems, halon and foam systems and all other fire protection systems.
- (5) Cutting holes in floors and walls for pipes:
  - With point and hammer.
  - Core-drilled.
- (6) The unloading, handling and storing of all the above.
- (7) All clean-up work.

Excluded are steam fire protection systems and stand pipes not connected to automatic sprinkler systems.

[Statutory Authority: Chapter 39.12 RCW, RCW 43.22.270 and 43.22.051. WSR 00-15-077, § 296-127-01375, filed 7/19/00, effective 7/19/00.]